



ADMINISTRATIVE SERVICES
Purchasing

1551 ROCK QUARRY ROAD
BUILDING F
RALEIGH, NORTH CAROLINA 27610
PHONE: 919.588.3444

WAKE COUNTY PUBLIC SCHOOLS

BID ADDENDUM UPDATE

BID Number: RFP 251-25-332

COMMODITY/SERVICE:

FIRE PUMP – WILBURN E.S.

ADDENDUM NAME:

ADDENDUM NUMBER: 1

QUESTION - ANSWER

BUYER: Jim Jaeger

RFP DUE DATE/TIME:
MARCH 5, 2025 2:00 pm ET

INSTRUCTIONS:

VENDOR QUESTIONS	WCPSS ANSWERS
<i>What are the conditions of service for the fire pump. What rated GPM@PSI is needed?</i>	Non serviceable 5 GPM@75PSI
<i>Is this for equipment only, no on-site service other than one day startup services/training?</i>	Equipment Only

**WITH THE POSTING OF THIS ADDENDUM, THIS RFP WILL BEGIN A “QUIET PERIOD”
UNTIL IT IS OPENED**

NO NEW QUESTIONS CAN BE ANSWERED