

### Questions for RFP #251-25-429 – Lighting Equipment Upgrades – Holly Springs High School

Reference	Vendor Question	Answers
	<p><b>THE DUE DATE FOR THE SUBMISSIONS HAS BEEN EXTENDED BY ONE WEEK. EMAIL BIDS ARE NOW DUE BY 5/20/25 AT 12:00 NOON.</b></p>	
	Is there a Touchscreen Layout and Diagram?	<p>There is not a specific layout. In general there should be:</p> <ul style="list-style-type: none"> <li>• A Page of house light presets including: <ul style="list-style-type: none"> <li>○ House Full</li> <li>○ House Half</li> <li>○ House Glow</li> <li>○ House Out</li> </ul> </li> <li>• A Page of custom presets: <ul style="list-style-type: none"> <li>○ Lable custom presets, “Preset 1”, “Preset 2” etc</li> </ul> </li> <li>• A Page to record presets, that is locked out via a passcode <ul style="list-style-type: none"> <li>○ Custom presets should be able to record any dmx value on universe 1, 2, 3 or 4 (Basically capture as much as possible)</li> </ul> </li> </ul>
	What is the wire pathway to the floor pocket?	Unknown – it can be completely abandoned. Vendors should note that in their proposals.
	How should gateways be configured?	<p>As follows:</p> <ul style="list-style-type: none"> <li>• House Dimmers and FOH dmx outputs are Universe 1</li> <li>• 1st and 2nd Electric are Universe 2</li> <li>• 2nd and 3rd Electric are Universe 3</li> <li>• Any other DMX outputs are Universe 4</li> </ul>
	Do both racks need the sensor 3 upgrades?	Only the rack with dimmers and power should be upgraded, the rack of AFMs does not need to be upgraded.
	Is the standard warranty sufficient?	Yes. Vendors shall indicate the warranty on any materials and labor provided in the bid.
	Is console training required?	No.
	Can we set up station lockout?	If Station lockout is desired by the end user, you are welcome to do so within the confines of the building code, however, we cannot answer if setting up station lockout meets code.