

## Questions for IFB #251-26-059 – Chiller Replacement

| # | Reference                 | Vendor Question  | Answers  |
|---|---------------------------|--|--|
| 1 | General                   | There is an advertisement for replacement of a 430Ton Carrier Chiller But there is no information as to the location or bidding documents.<br>Is there some way for me to gain access to this bidding information? | Wake Forest High School<br>420 W. Stadium Ave.<br>Wake Forest, NC 27587  |
| 2 | Warranty, Page 17 of 27   | Confirm warranty covered listed in Spec Section 1.8.A. Does the school want 5 Year Parts and Labor for just the Compressor Only or the Whole Chiller?  | Warranty shall consist of full unit for 5 years.<br>This shall include all components, compressors, refrigerant and labor. |
| 3 | Insulation, Page 20 of 27 | Confirm if standard 3/4in insulation is acceptable in spec section 2.9.A.1?  | $\frac{3}{4}$ " is acceptable  |

**WITH THE POSTING OF THIS ADDENDUM, THIS IFB WILL BEGIN A "QUIET PERIOD UNTIL IT IS OPENED"**

**NO NEW QUESTIONS CAN BE ANSWERED**