

Questions for IFB #251-26-060 – Chiller Replacement

#	Reference	Vendor Question	Answers
1	Warranty, Page 17 of 26	Confirm warranty covered listed in Spec Section 1.8.A. Does the school want 5 Year Parts and Labor for just the Compressor Only or the Whole Chiller?	Warranty shall consist of full unit for 5 years. This shall include all components, compressors, refrigerant and labor.
2	Insulation, Page 20 of 26	Confirm if standard 3/4in insulation is acceptable in spec section 2.9.A.1?	¾" is acceptable
3	General	There is an advertisement for Carrier Chiller, but there is no information as to the location.	Mt. Vernon Middle School

WITH THE POSTING OF THIS ADDENDUM, THIS IFB WILL BEGIN A "QUIET PERIOD UNTIL IT IS OPENED"

NO NEW QUESTIONS CAN BE ANSWERED