

Questions for IFB #251-26-061 – Chiller Replacement

#	Reference	Vendor Question	Answers
1	Warranty, Page 17 of 37 and Page 27 of 37	Confirm warranty covered listed in Spec Section 1.8.A. Does the school want 5 Year Parts and Labor for just the Compressor Only or the Whole Chiller?	Warranty shall consist of full unit for 5 years. This shall include all components, compressors, refrigerant and labor.
2	Insulation, Page 20 of 37 and Page 30 of 37	Confirm if standard 3/4in insulation is acceptable in spec section 2.9.A.1?	¾" is acceptable
3	General	There is an advertisement for Carrier Chiller, but there is no information as to the location.	Enloe High School

WITH THE POSTING OF THIS ADDENDUM, THIS IFB WILL BEGIN A "QUIET PERIOD UNTIL IT IS OPENED"

NO NEW QUESTIONS CAN BE ANSWERED