

Questions for RFP #251-27-95 – FIRE SUPPRESSION INSPECTION AND CERTIFICATION

Reference	Vendor Question	Answers
	Will the new reporting to LivSafe need to be part of the base system inspection price or added as an addendum line item price?	This will need to be part of the base system inspection price.
	Your newer schools have the Captive Aire Tank systems in them. Will you provide a separate base line item for those inspections in an addendum?	Yes, an addendum will be posted.
	Will the following items, which are required to be changed annually or sooner if needed, be added to an addendum for pricing? • Rubber nozzle caps (ANSUL / Pyro-Chem) (Annually) • Metal nozzle caps (if damaged) (ANSUL /Pyro-Chem) • Nozzle O-rings (for metal nozzle caps) (ANSUL / Pyro-Chem) (Annually) • 16gram Actuation Cartridge (Pyro-Chem) (Annually)	Rubber Nozzle Caps, • Annual Replacement – NO • If missing or damaged – YES Metal Nozzle Caps • Annual Replacement – NO • If missing or damaged – YES Nozzle O-Rings for Metal Nozzle Caps • Annual Replacement – NO • If missing or damaged – YES 16gram Actuation Cartridge (Pyro-Chem) • Annual Replacement - NO
	Will the following items be added to an addendum for pricing for items needed during 12-year maintenance? • Regulator test (ANSUL) • Expellant hose (ANSUL) • 101-20 Cartridge (ANSUL) • LT-20 Cartridge (ANSUL) • LT-30 Cartridge (ANSUL) • Double Tank Cartridge (ANSUL) • Actuation Hose (Amerex) • Distribution Hose (Amerex) • Nitrogen Actuation Cylinder (Amerex) • Batteries (Captive Aire Tank System) (Every Two Years)	Yes, a pricing addendum will be posted.