



ADMINISTRATIVE SERVICES
Purchasing

1551 ROCK QUARRY ROAD
BUILDING F
RALEIGH, NORTH CAROLINA 27610
PHONE: 919.588.3444

WAKE COUNTY PUBLIC SCHOOLS

BID ADDENDUM UPDATE

BID Number: **251-23-363**

COMMODITY/SERVICE:

Chiller Replacement Units

ADDENDUM NAME:

ADDENDUM Number: **1**

QUESTION-ANSWER

BUYER: **Jim Jaeger**

RFP DUE DATE/TIME:
FEBRUARY 21, 2023 2:00 pm ET

INSTRUCTIONS: **ANSWERS TO RFP QUESTION(S) ON PAGE 2**

WCPSS RFP 251-23-363

CHILLER REPLACEMENT UNITS

WITH THE POSTING OF THIS ADDENDUM, THIS RFP WILL BEGIN A “QUIET PERIOD” UNTIL IT IS OPENED

NO NEW QUESTIONS CAN BE ACCEPTED

VENDOR QUESTIONS	WCPSS ANSWERS
<p><i>Page 15 under the section “Important Notes”, it states to provide a 180T air-cooled chiller. On page 16, note 9 of the mechanical schedule it indicates a nominal 200T Dunham-Bush Chiller, Model ACHX-DVE200.</i></p> <p><i>Does Wake County require a nominal 200T or nominal 180T machine?</i></p>	<p>WCPSS is specifying an air cooled chiller with a minimum delivered total cooling capacity of 180 tons at design conditions.</p> <p>Manufacturer can select whatever nominal ton chiller meets this requirement, but from previous submission we determined the ACHX-DVE200 met this requirement.</p>
<p><i>Page 16 under the section “Important Notes”, it states to provide two 180T air-cooled <u>screw</u> chillers, however on page 1 of the spec 236426 section F & G (page 18 of 21 of the pdf) it lists both screw and scroll compressors.</i></p> <p><i>Please confirm both screw and scroll compressor technologies are acceptable?</i></p>	<p>Chillers shall may either be screw or scroll compressors as long as they meet the equipment schedule and specification requirements</p>
<p><i>Spec 236426 section H (page 18 of 21 of the pdf)</i></p> <p><i>Is a strainer required by the chiller vendor?</i></p>	<p>No, this will be provided by mechanical contractor</p>
<p><i>Specification Section 236426 Air Cooled Water Chillers:E. “Carrier / JCI/York / Dunham Bush”</i></p> <p><i>Chiller Schedule:Basis of Design “Trane RTAA”</i></p> <p><i>Is Trane an acceptable bidder?</i></p>	<p>The RTAA noted in the basis of design is the existing chiller. Trane is acceptable if it meets the specification requirements</p>
<p><i>Page 2 and page 16</i></p> <p><i>As a vendor do I need to fill out the table(s) on this page?</i></p>	<p>Yes, complete where requested</p>
<p><i>Page 5, Qualifications tab / Page 5 T&C's</i></p> <p><i>As a vendor do I need to provide any proof of insurance to provide an equipment proposal?</i></p>	<p>No</p>
<p><i>Page 11, Attachments As a vendor do I need to fill out the corresponding tables under the Attachments A tab ?</i></p>	<p>Yes, complete anything applicable</p>
<p><i>Page 12, MBE information & Page 13, Identification of Historically Underutilized....</i></p> <p><i>As a vendor do I need to fill out the MBE form table?</i></p> <p><i>As a vendor do I need to fill out this entire page?</i></p>	<p>Yes, if possible, but not required</p>