

ADMINISTRATIVE SERVICES Purchasing

1551 ROCK QUARRY ROAD Building f Raleigh, North Carolina 27610 **Phone:** 919.588.3444

WAKE COUNTY PUBLIC SCHOOLS BID ADDENDUM UPDATE

BID Number:		<u>COMMODITY/SERVICE:</u>
	24-140	LITH HIGH BAY LIGHTS
ADDENDUM Number:	1	ADDENDUM NAME: QUESTION-ANSWER
BUYER:	Jim Jaeger	<u>RFP DUE DATE/TIME:</u> JULY 21, 2023 2:00 pm ET

INSTRUCTIONS: ANSWERS TO RFQ QUESTION(S)

RFP 24-140	M+O Bid Title: LITH HIGH BAY LIGHTING
VENDOR QUESTIONS	WCPSS ANSWERS
I need some information regarding bid # 24-140, can you please confirm what kind of reflector and finish you want? Does this Highbay require reflector? It doesn't show on the item's description.	Yes, There should be a clear reflector with a wire guard on the bottom.
Is substitutes or equivalents will be considered for these lighting fixtures.	Substitutes must be deemed equal or better by the requesting department.

This RFP is now in a quiet period.

No further questions can be answered, unless directly effecting the bid.