

## ADMINISTRATIVE SERVICES Purchasing

1551 ROCK QUARRY ROAD
BUILDING F
RALEIGH, NORTH CAROLINA 27610
PHONE: 919.588.3444

## **WAKE COUNTY PUBLIC SCHOOLS**

## **BID ADDENDUM UPDATE**

**BID Number:** 

251-24-230

**COMMODITY/SERVICE:** 

**Chiller Replacement Units-ARMS** 

ADDENDUM NAME:

ADDENDUM NUMBER: QA-1

**QUESTION-ANSWER** 

BUYER: Jim Jaeger

RFP DUE DATE/TIME:
September 26, 2023 2:00 pm ET

## INSTRUCTIONS: INCLUDES ANSWERS TO RFP QUESTIONS

RFP 251-24-230 M+O Bid: Chiller Replacement Units (ARMS)

VENDOR QUESTIONS	WCPSS ANSWERS
The mechanical schedule calls for Bacnet, whereas the specification calls for Lonworks. Can you confirm which controls language you require for both of the schools?	Chillers shall be provided with Bacnet Communications for both projects.

WITH THE POSTING OF THIS ADDENDUM, THIS RFP WILL BEGIN A "QUIET PERIOD" UNTIL IT IS OPENED

NO NEW QUESTIONS CAN BE ANSWERED