



ADMINISTRATIVE SERVICES
Purchasing

1551 ROCK QUARRY ROAD
BUILDING F
RALEIGH, NORTH CAROLINA 27610
PHONE: 919.588.3444

WAKE COUNTY PUBLIC SCHOOLS

BID ADDENDUM UPDATE

BID Number: **251-24-303**

COMMODITY/SERVICE:

CHILLER REPLACEMENT UNIT - CHS

ADDENDUM NAME:

ADDENDUM NUMBER: **QA-1**

QUESTION-ANSWER

BUYER: Jim Jaeger

RFP DUE DATE/TIME:

December 8, 2023 2:00 pm ET

INSTRUCTIONS: **ADDENDUM INCLUDES WCPSS RESPONSES TO VENDOR RFP
QUESTIONS**

**WITH THE POSTING OF THIS ADDENDUM, THIS RFP WILL BEGIN A "QUIET PERIOD"
UNTIL IT IS OPENED**

NO NEW QUESTIONS CAN BE ANSWERED

RFP 251-24-303 Chiller Replacement Unit – CHS

VENDOR QUESTIONS	WCPSS ANSWERS
<i>I am writing to see if there's a possibility to bid on installing the chillers the you guys are getting bids for.</i> <i>I couldn't find anything stating that the winner bidder is responsible for installing the chiller – is that the case for all these bids? If so, I can get with our engineering team and submit some for York chillers for these schools if ACR would be responsible for installing. If you could let me know, I would appreciate will work on getting bids put together for ya.</i>	The current bids are commodity purchases only. No install should be quoted. Delivery will be coordinated by our FAL dept. and their contractor. Installation service contracts are a separate "Term Contract" bid. M&O Service Term Contracts are bid or renewed for each fiscal year (July to July). Normally these new bids are posted to the eVP and WCPSS websites around the second week of March.
<i>What is the want date for the chillers?</i>	There is no specified delivery date.
<i>410a refrigerant is no longer available, does 454B work?</i>	For scroll chillers shall be R-410a as specified.