## **Questions for RFP #251-24 –325**

Reference	Vendor Question	Answers
BID # 251-24-325	1. There's a couple light spill metrics in the spec – 1.5 fc horizontal at property line for "cutoff" lights, 0.4 fc for non-cutoff, and 12,000 candela at nearby properties. First two seem like Town of Cary ordinances and the candela requirement is another manufacturer Musco Lighting item. Need to know what we will be held to. Are we to assume to comply with the Town of Cary lighting ordinance?	Delete the reference to 12,000 candela at nearby properties, it is not a Town of Cary requirement. Comply with the Town of Cary Lighting Ordinance
	2. EM light levels are applicable to "POE" path of egress which are basically the bleachers and right around them, which can be handled by sports poles, plus a path out to the exit gate on the NE corner. Will we need to aim a sports lighting fixture to the NE gate? Or is there another light source for that area (Wall pack on field house? Bollard or decorative fixture along pathway?)	There are no other sources for the POE lighting. You can add another light to the pole if needed to provide the POE lighting

## RFP #251-24-325 - ADDENDUM 1